

Colorado Department of Public Health and Environment
Water Quality Control Division
WQCD-B2-CWE
ATTN: Aly Ulibarri
4300 Cherry Creek Drive South
Denver, Colorado 80246-1530

RECEIVED

DEC 13 2019


WATER QUALITY
CONTROL DIVISION

Response to compliance advisory dated 11-22-2019 for the City of Creede CDPS Number CO0040533.

Creede had a BOD violation on 9-1-2019 of 35 mgL and our limit is 30 mgL. We don't know why it happened, but to help correct the issue, we intend to add commercial micro-organisms to help digest the BOD better.

We also had E coli numbers of 1679 which was over our 30-day and 7-day limits. This was caused by lack of chlorination during that time because our chlorination equipment was inactive. We are now purchasing replacement equipment and will install it as soon as we receive it to resume chlorination and de-chlorination.

Thank you,



Fred Hand, ORC
City of Creede