

July 15, 2020

Aly Ulibarry, CDPHE  
Enforcement Specialist  
Clean Water Enforcement Unit  
Water Quality Control Division

RE: Response to Compliance Advisory, Creede WWTF, CO0040533

Dear Aly,

This letter is in response to the violation for the month of April 2020 when Creede had a pH reading of 9.5. This high pH reading is due to a sudden increase in algae. To correct this situation, Creede intends to increase aeration which will help reduce the algae.

As of today's date, 7/15/20, the algae has already decreased and we expect future pH readings to be in compliance.

Fred Hand, ORC  
SCWO, LLC  
719-850-0075